

**GENERAL CERTIFICATE OF EDUCATION BOARD**

Technical and Vocational Education Examination

**JUNE 2021**

**ADVANCED LEVEL**

Specialty Name / Code	Electrical Power Systems (EPS )
Subject Title	Design of Electrical Installations
Subject Code N°	7245
Paper N°	2

**Three hours**

The paper has Two Sections (A and B) and constitutes 35% of the whole subject.

**Section A has ONE COMPULSORY QUESTION, carrying 40 marks.**

**Section B has FOUR QUESTIONS, each carrying 30 marks. ANSWER ANY TWO QUESTIONS.**

All sketches must be neat and clear.

You are allowed the use of Electronic calculators and mathematical sets.

No programmable calculators are allowed

You are also reminded of the necessity for good English and orderly presentation in your answers.

You are advised to read carefully through the question paper, before you begin your answers.

We want to realize a preliminary design of electrical installation of a newly created GTHS which will offer three trades for the beginning, consisting of three workshops, an administrative block and twelve (12) class rooms.

## I. General Presentation.




Figure 1: General Line Diagram of the Installation

## II. Presentation of the Different Blocks.

### Workshop A : Motor mechanics.

- Six (06) 1-ph motors:  $P = 1.5kW$ ;  $\cos \varphi = 0.70$ ;  $\eta = 0.7$  each.  $K_S = 0.75$ ;  $K_U = 0.8$
- Eight (08) 1-ph socket-outlets of  $2P + T$ ; 16A, 220V each.
- 30 fluorescent tubes of  $40W$ ;  $\cos \varphi = 0.86$ .
- A 15kW compressor of  $\cos \varphi = 0.85$ ;  $\eta = 0.7$ ;  $K_U = 0.8$
- A 15kW lift of  $\cos \varphi = 0.75$ ;  $\eta = 0.75$ ;  $K_U = 0.8$

### Workshop B: Mechanical manufacturing.

- Twenty (20) compensated fluorescent tubes of  $58W$ ;  $\cos \varphi = 0.86$  each.
- Ten (10) 1-ph socket-outlets of  $2P + T$ ; 16A, 220V each.
- Four (04) 1-ph motors of:  $P = 2.2kW$ ;  $\cos \varphi = 0.80$ ;  $\eta = 0.75$   $K_S = 0.75$ ;  $K_U = 0.8$
- Three (03) 3-ph motors with power  $P = 18.5kW$ ;  $\cos \varphi = 0.90$ ;  $\eta = 0.85$  each.  $K_S = 0.75$ ;  $K_U = 0.8$
- A 5kW milling machine of;  $\cos \varphi = 0.86$ ;  $\eta = 0.75$ ;  $K_U = 0.8$
- Four (04) 5kW lathes machines,  $\cos \varphi = 0.75$ ;  $\eta = 0.85$  each.  $K_S = 0.75$ ;  $K_U = 0.8$

Go on to the next page

**Workshop C: Carpentry**

- A planer of  $P = 10kW$ ;  $\cos \varphi = 0.85$ ;  $\eta = 0.9$ ;  $K_U = 0.8$
- Nine (09) grinders of:  $P = 1.6kW$ ;  $\cos \varphi = 0.8$ ;  $\eta = 0.9$  each.  $K_S = 0.75$ ;  $K_U = 0.8$
- A jointer of:  $P = 7kW$ ;  $\cos \varphi = 0.8$ ;  $\eta = 0.9$ ;  $K_U = 0.8 = 7KW$ ;  $\cos \varphi = 0.80$ ;  $\eta = 0.9$ .  $K_U = 0.8$
- Eighteen (18) compensated fluorescent tubes in twin mounting of:  $40W$ ;  $\cos \varphi = 0.86$  each
- Two (02) sanders of:  $P = 1.5kW$ ;  $\cos \varphi = 0.80$ ;  $\eta = 0.9$  each.  $K_S = 0.75$ ;  $K_U = 0.8$
- Two (02) circular saws of:  $P = 3kW$ ;  $\cos \varphi = 0.85$ ;  $\eta = 0.75$  each.  $K_S = 0.75$ ;  $K_U = 0.8$

**Administrative block and Class Room :**  $K_S = K_U = 1$

- Three (03) air conditioners of:  $P = 2.5kW$ ;  $\cos \varphi = 0.85$ ;  $\eta = 0.75$  each.
- Twenty-one (21) lighting fittings carrying two fluorescent tubes of:  $P = 10kW$ ;  $\cos \varphi = 0.86$  each.
- Twelve (12) 1-ph socket-outlets of:  $2P+T$ ; 16A, 220V each.
- Two (02) refrigerators of  $P = 2kW$ ;  $\cos \varphi = 0.86$ ;  $\eta = 0.75$  each.
- Eight (08) 1-ph socket-outlets of:  $2P+T$ ; 16A, 220V each, in each class room.
- Five (05) lighting fittings carrying two fluorescent tubes of:  $P = 40kW$ ;  $\cos \varphi = 0.86$  each, in each class room.

**NB :**

- The power lost in the ballast of each fluorescent tube is estimated at 25% of the rated power of the tube.
- The simultaneity factors to be applied to the whole administrative/classrooms and workshops switchgear console are 1 and 1.
- The ambient temperature of the entire structure is  $40^{\circ}\text{C}$ .
- For sockets  $K_S = 0.1 + \frac{0.9}{N}$  (with  $N \leq 5$  number of sockets per circuit) and  $K_U = 1$ .

**Section A. (COMPULSORY)****1. Power demand and choice of transformer**

- Complete appendix 1 by calculating the:
    - active, reactive, apparent powers absorbed, the currents absorbed and power factors in each block.
    - active, reactive, apparent powers absorbed, the total current absorbed in the whole installation and the overall power factor the whole installation(5 marks×4)
  - Using appendix 2, choose the appropriate transformer specifying its characteristics, including ( $S_n$ ,  $U_{sc}$ ,  $U_{20}$ ,  $I_n$  and  $I_{sc}$ ) knowing that for reasons of extension of the installation, the power previously calculated as 248 KVA is to be increased by 40%. (15 marks)
- (5 marks)

**Section B****2. Power factor improvement.**

The power factor of the overall installation is to be improved from 0.88 to 0.93. The overall installation active power is assumed to be 220 kW, the rated apparent power ( $S_n$ ) of the transformer to be 400 kVA.

- Determine the corrected power  $Q_c$  and the ratio of the correction  $\frac{Q_c}{S_n}$  to be installed using appendix 3 and precise the type of compensation. (15 marks)
- Use appendix 4 to select:
  - the type of network using appendix 4 for  $\frac{G_h}{S_n} = 26\%$
  - the type of compensation for  $\frac{Q_c}{S_n} \leq 15\%$ . (7 marks)

### 3. Selection of cables sizes.

Table 1 gives the characteristics of cables. All the cables are made of copper and placed together, under a temperature of 40 °C.

Cable labelling	Length (m)	Current absorbed (A) (A)	Nature of the insulator	Laying method
CS <sub>0</sub>	6	365	XLPE	Multi-core cable installed alone on perforated cable tray.
CS <sub>1</sub>	35	320	XLPE	Multi-core cable placed on perforated tray with 2 other circuits.
CS <sub>2</sub>	40	45	PVC	Single-core cable laid with 4 other circuits on un-perforated cable tray.
CS <sub>3</sub>	40	130	XLPE	PVC multicore cable laid alone under spaces in buildings.

Table 1: Characteristics of cables

Cable labelling	Insulator	Letter of selection	Correction Factor (k <sub>1</sub> , k <sub>2</sub> , k <sub>3</sub> )	Current Absorbed (A)	Current Corrected (A)	C.S.A. (mm <sup>2</sup> )
CS <sub>0</sub>						
CS <sub>1</sub>						
CS <sub>2</sub>						
CS <sub>3</sub>						

Table 2

Determine, using the manufacturer documents of Appendix 5 and 6, the standard cross sectional area of the cables based on the characteristics provided, by filling in the table 2. (30 marks)

### 4. Selection of circuit breakers.

- a) Determine, using appendix 7, the length of cables in table 1 and the upstream I<sub>SC</sub> of the chosen transformer of 14.2kA the downstream short-circuit currents at the following points:
  - i. BB1 busbar; S=185mm<sup>2</sup> (2.5 marks)
  - ii. BB2 busbar; S=185mm<sup>2</sup> (2.5 marks)
  - iii. Administrative block and Class Rooms. CS=25mm<sup>2</sup> (2.5 marks)
- b) Choose the circuit breakers (CB<sub>1</sub>, CB<sub>2</sub>, CB<sub>3</sub>, CB<sub>4</sub> and CB<sub>5</sub>) using the manufacturer documents of appendix 8a & 8b by filling table 3. (22.5 marks)

Labelling	Type (reference)	Calculated current (A)	Nominal Current (A)	Nominal Voltage (V)	Number of poles	Breaking Capacity(kA)
CB <sub>1</sub>		350				
CB <sub>2</sub>		61				
CB <sub>3</sub>		127				
CB <sub>4</sub>		130				
CB <sub>5</sub>		61				

Table 3

### 5. Lighting pre-project

You are also entrusted with the study of the lighting project of the multi-purpose hall which is under construction in the complex, whose characteristics are as follows:

- Size of the multi-purpose hall: 50m × 20m ; working height : 7.20 m ;
- Reflection factor of walls: Ceiling 50%, Wall 30%, Useful plan 30%;
- Average luminance level for general lighting: 300 lux ;
- Light sources: fluorescent mercury vapor lamp or high pressure sodium vapor lamp.

- Lighting fixture: a semi-intensive, bright, anodized aluminum direct reflector capable of using any of the selected sources;  $\eta = 0.7$
- Easy maintenance, relatively low total installation cost, low dust level.
- Depreciation factor  $d=1,25$ .

According to the specifications above, and using appendix 9:

- a. Determine the total luminous flux to be produced. (10 marks)
  - b. Determine the number of devices for each of the proposed sources. (8 marks)
  - c. Choose the most economical solution to determine the number of lamps to install and propose the plan of distribution of the lighting fittings by respecting the standard. (12marks)
-

**Appendix 2 (Q1b)****TABLE OF CHARACTERISTICS OF HV/LV TRANSFORMERS.****MAXIMUM SHORT-CIRCUIT CURRENT FROM DOWNSTREAM OF A TRANSFORMER MV/LV**

The values indicated in the table below correspond to a three-phase short-circuit bolted at the terminals of a MV/LV transformer connected to a network whose short-circuit power in MV is 500 MVA at 20 kV.

	Ratings of transformers in KVA													
	50	63	80	100	125	160	200	250	315	400	500	630	800	1000
<b>220V</b>														
<b>I<sub>n</sub>(A)</b>	120	157	200	250	313	400	500	625	789	1000	1250	1575	2000	2500
<b>I<sub>sc</sub>(KA)</b>	3.1	3.9	4.8	6.2	7.8	9.9	12.4	15.4	19.4	24.5	31.2	38.2	38.35	44.4
<b>U<sub>sc</sub>(%)</b>	4	4	4	4	4	4	4	4	4	4	4	4	4	
<b>Copper losses (kW)</b>	1.1	1.1	1.1	1.8	1.8	2.4	2.85	3.25	3.9	4.81	5.95	6.95	12	13.9
<b>380V</b>														
<b>I<sub>n</sub>(A)</b>	72	91	115	140	180	232	290	360	450	580	720	910	1155	1445
<b>I<sub>sc</sub>(KA)</b>	1.8	2.3	2.9	3.7	4.5	5.7	7.14	8.9	11.2	14.2	17.6	22.1	24.8	27.8
<b>U<sub>sc</sub>(%)</b>	4	4	4	4	4	4	4	4	4	4	4	4	4.5	5
<b>Copper losses (kW)</b>	1.1	1.1	1.1	1.8	1.8	2.4	2.85	3.25	3.9	4.81	5.5	6.95	10.2	12.1

**APPENDIX 9 (Q5)**

		Reflection Factors (%)													
Ceiling		70			50			30			70			50	
Walls		50	30	10	50	30	10	30	10	50	30	10	50	0	
Useful plan		10			30			30			30				
K	0.60	0.42	0.37	0.34	0.41	0.37	0.34	0.37	0.34	0.44	0.38	0.35	0.43	0.38	0.33
	0.80	0.48	0.44	0.41	0.48	0.44	0.41	0.43	0.41	0.51	0.46	0.42	0.50	0.45	0.39
	1.00	0.54	0.50	0.47	0.53	0.49	0.46	0.49	0.46	0.57	0.52	0.48	0.56	0.51	0.45
	1.25	0.58	0.55	0.52	0.57	0.54	0.51	0.53	0.51	0.63	0.58	0.54	0.61	0.56	0.50
	1.50	0.62	0.58	0.56	0.60	0.57	0.55	0.57	0.55	0.67	0.62	0.58	0.64	0.60	0.53
	2.00	0.66	0.64	0.61	0.65	0.63	0.61	0.62	0.60	0.73	0.66	0.65	0.70	0.66	0.59
	2.50	0.69	0.65	0.69	0.68	0.66	0.64	0.65	0.63	0.77	0.73	0.70	0.73	0.70	0.62

Table 4: Utilance Factors

	Mercury vapour lamp with fluorescent balloon	High pressure sodium lamp
Life Span	6000 hours	6000 hours
Power	400 W	400 W
Losses due to choke	22 W	22 W
Flux emitted by lamp	22.000 Lm	47.000 Lm
Cost of fixture +	9000frs CFA	13500frs CFA

Table 5: Characteristics of lamps

## APPENDIX 3 (Q2a)

## REQUIRED REACTIVE POWER KVAR PER KW TO IMPROVE THE POWER FACTOR

The capacitors improve the power factor only on the part of the installation situated before their point of connection. they shall be placed near appliances consuming reactive energy

Before Improvement	Power of Capacitor in KVAR to be installed per KW of load to improve the power factor													
	$\tan \phi$	0.75	0.59	0.48	0.46	0.43	0.4	0.36	0.33	0.29	0.25	0.20	0.14	0
$\tan \phi$	$\cos \phi$	0.80	0.86	0.9	0.91	0.92	0.93	0.94	0.95	0.96	0.97	0.98	0.99	1
2.29	0.4	1.55	1.69	1.80	1.83	1.861	1.89	1.924	1.95	1.99	2.03	2.08	2.146	2.288
2.22	0.41	1.47	1.62	1.74	1.76	1.798	1.83	1.840	1.89	1.93	1.97	2.02	2.082	2.225
2.16	0.42	1.41	1.56	1.68	1.70	1.738	1.77	1.800	1.83	1.87	1.91	1.96	2.022	2.164
2.10	0.43	1.35	1.49	1.62	1.65	1.680	1.71	1.742	1.77	1.81	1.85	1.90	1.964	2.107
2.04	0.44	1.29	1.44	1.55	1.58	1.614	1.64	1.677	1.71	1.75	1.79	1.83	1.899	2.041
1.98	0.45	1.23	1.38	1.50	1.53	1.561	1.59	1.628	1.65	1.69	1.73	1.78	1.846	1.988
1.93	0.46	1.17	1.33	1.44	1.47	1.502	1.53	1.567	1.60	1.63	1.67	1.72	1.786	1.929
1.88	0.47	1.13	1.27	1.39	1.42	1.454	1.48	1.519	1.53	1.58	1.62	1.67	1.758	1.881
1.83	0.48	1.07	1.22	1.34	1.37	1.400	1.43	1.464	1.49	1.53	1.57	1.62	1.684	1.826
1.78	0.49	1.03	1.17	1.29	1.32	1.355	1.38	1.420	1.45	1.48	1.53	1.57	1.639	1.782
1.73	0.50	0.96	1.13	1.24	1.27	1.303	1.33	1.369	1.40	1.44	1.48	1.52	1.590	1.732
1.69	0.51	0.93	1.08	1.20	1.23	1.257	1.29	1.323	1.35	1.39	1.43	1.48	1.544	1.686
1.64	0.52	0.89	1.04	1.16	1.18	1.215	1.24	1.281	1.31	1.35	1.39	1.44	1.502	1.644
1.60	0.53	0.85	1.00	1.11	1.14	1.171	1.20	1.237	1.27	1.30	1.34	1.37	1.458	1.600
1.56	0.54	0.80	0.95	1.07	1.10	1.130	1.16	1.196	1.23	1.26	1.30	1.35	1.417	1.559
1.52	0.55	0.76	0.91	1.03	1.06	1.090	1.12	1.156	1.19	1.22	1.26	1.31	1.377	1.519
1.48	0.56	0.73	0.87	0.99	1.02	1.051	1.08	1.117	1.15	1.18	1.22	1.27	1.338	1.480
1.44	0.57	0.69	0.84	0.95	0.98	1.013	1.04	1.079	1.11	1.15	1.19	1.23	1.300	1.442
1.40	0.58	0.66	0.80	0.92	0.94	0.976	1.01	1.042	1.07	1.11	1.15	1.20	1.263	1.405
1.37	0.59	0.61	0.76	0.88	0.91	0.939	0.97	1.005	1.03	1.07	1.11	1.16	1.226	1.368
1.33	0.60	0.58	0.73	0.84	0.87	0.905	0.93	0.971	1.00	1.04	1.08	1.13	1.192	1.334
1.30	0.61	0.54	0.69	0.81	0.84	0.870	0.90	0.936	0.97	1.00	1.04	1.09	1.157	1.299
1.27	0.62	0.51	0.66	0.78	0.80	0.838	0.87	0.902	0.93	0.97	1.01	1.06	1.123	1.265
1.23	0.63	0.48	0.63	0.74	0.77	0.804	0.83	0.870	0.90	0.94	0.98	1.03	1.091	1.233
1.20	0.64	0.45	0.60	0.71	0.74	0.771	0.80	0.837	0.87	0.90	0.94	0.99	1.058	1.200
1.17	0.65	0.41	0.56	0.68	0.71	0.740	0.77	0.806	0.84	0.87	0.91	0.96	1.007	1.169
1.14	0.66	0.38	0.53	0.65	0.68	0.709	0.74	0.775	0.80	0.84	0.88	0.93	0.996	1.138
1.11	0.67	0.35	0.50	0.62	0.65	0.679	0.71	0.745	0.77	0.81	0.85	0.90	0.966	1.108
1.08	0.68	0.32	0.47	0.59	0.62	0.650	0.68	0.716	0.75	0.78	0.82	0.87	0.937	1.079
1.05	0.69	0.29	0.44	0.56	0.59	0.620	0.65	0.686	0.72	0.75	0.79	0.84	0.907	1.049
1.02	0.70	0.27	0.42	0.53	0.56	0.591	0.62	0.657	0.69	0.72	0.76	0.81	0.878	1.020
0.99	0.71	0.24	0.39	0.50	0.53	0.563	0.59	0.629	0.66	0.70	0.74	0.78	0.850	0.992
0.96	0.72	0.21	0.36	0.47	0.50	0.534	0.56	0.600	0.63	0.67	0.71	0.75	0.821	0.963
0.94	0.73	0.18	0.33	0.45	0.48	0.507	0.54	0.573	0.60	0.64	0.68	0.72	0.794	0.936
0.91	0.74	0.15	0.30	0.42	0.45	0.480	0.51	0.546	0.58	0.61	0.65	0.70	0.767	0.909
0.88	0.75	0.13	0.36	0.39	0.42	0.453	0.48	0.519	0.55	0.59	0.63	0.67	0.740	0.882
0.86	0.76	0.10	0.33	0.37	0.39	0.426	0.46	0.492	0.52	0.56	0.60	0.65	0.713	0.855
0.83	0.77	0.07	0.30	0.34	0.37	0.400	0.43	0.466	0.50	0.53	0.57	0.62	0.687	0.829
0.80	0.78	0.05	0.20	0.31	0.34	0.374	0.40	0.440	0.47	0.51	0.55	0.59	0.661	0.803
0.78	0.79	0.02	0.17	0.29	0.32	0.347	0.38	0.413	0.44	0.48	0.52	0.56	0.634	0.776
0.75	0.80	0.15	0.26	0.29	0.321	0.35	0.387	0.42	0.45	0.49	0.54	0.608	0.750	
0.72	0.81	0.12	0.24	0.26	0.295	0.32	0.361	0.39	0.43	0.47	0.51	0.582	0.724	
0.70	0.82	0.09	0.21	0.24	0.269	0.30	0.335	0.36	0.40	0.44	0.48	0.556	0.698	
0.67	0.83	0.07	0.18	0.21	0.243	0.27	0.309	0.34	0.38	0.42	0.46	0.530	0.672	
0.65	0.84	0.04	0.16	0.19	0.217	0.25	0.283	0.31	0.35	0.39	0.43	0.504	0.645	
0.62	0.85	0.02	0.13	0.16	0.191	0.22	0.257	0.29	0.32	0.36	0.41	0.478	0.620	
0.59	0.86	0.10	0.14	0.167	0.19	0.230	0.26	0.30	0.34	0.39	0.450	0.593		
0.57	0.87	0.08	0.11	0.141	0.17	0.204	0.23	0.27	0.31	0.36	0.424	0.567		
0.54	0.88	0.05	0.08	0.112	0.14	0.175	0.20	0.24	0.28	0.33	0.395	0.538		
0.51	0.89	0.02	0.05	0.086	0.11	0.149	0.18	0.23	0.26	0.30	0.369	0.512		
0.48	0.90	0.03	0.058	0.08	0.121	0.15	0.19	0.23	0.28	0.341	0.484			

**Choice of the mode of reactive energy compensation: Global-Partial-Individual.**

Three modes of compensations in function of the location of equipment:

- The global compensation is case 1.
- The partial compensation is case 2.
- The individual compensation is case 3.

**Choice of the type of compensation: Fixed or Automatic.**

The ratio  $Qc/Sn$  guides in the choice between a fixed compensation equipment or an automatic compensation equipment in the cases of global or partial compensations.


- $Qc/Sn \leq 15\%$  : fixed compensation.
- $Qc/Sn > 15\%$ : automatic compensation.

**Selection of the type of reactive energy compensation equipment.**

There are three types of compensation equipment based on the level of the harmonic pollution of the network:

- If  $Gh/Sn \leq 15\%$ , the equipment to use is the **standard** type.
- If  $15\% < Gh/Sn \leq 25\%$ , the equipment to use is type **H**.
- If  $25\% < Gh/Sn \leq 60\%$ , the equipment to use is type **SAH**.

Appendix 4(/Q2b)



**Sn:** Apparent power of the transformer.

**Gh :** Apparent power of equipment producing harmonic.

**Qc:** Power of the compensation equipment.

Q/S $\leq 15\%$ Fixe improvement		Nature of the Network	Q/S $> 15\%$ Automatic improvement	
Standard type		Standard network	Standard type	
Without protection circuit breaker	With protection circuit breaker		Rectimat	Secomat
Varplus M	Rectibloc			22.5 to 180 kVAR Compensation equipment Prisma
10 to 100 kVAR High power Varplus	Rectibloc	$Gh/Sn \leq 15\%$		22.5 to 720 kVAR 150 to 720 kVAR
100 to 140 kVAR	10 to 120 kVAR			
Type H	Polluted network			Type H
Without protection circuit breaker	With protection circuit breaker		Rectimat	Secomat
Varplus M	Rectibloc			25 to 120 kVAR Compensation equipment Prisma
10 to 100 kVAR High power Varplus	Rectibloc	$15\% < Gh/Sn \leq 25\%$		160 to 540 kVAR
100 to 140 kVAR	10 to 120 kVAR			
Type SAH	Highly Polluted network			Type SAH
Without protection circuit breaker	With protection circuit breaker			Secomat and Prisma Cabinets
High power Varplus	Rectibloc			25 to 200 kVAR Compensation equipment Prisma
12.5 to 150 kVAR	25 to 150 kVAR	$25\% < Gh/Sn \leq 60\%$		150 to 600 kVAR

Appendix 5/ Q3

Go on to the next page

## APPENDIX 5 (Q3)

REFERENCE METHOD		
Type of cables	Laying Method	Reference method
Single or multi-core cables	In visible or embedded conduits and chutes In spaces in buildings, In gutters, mouldings, plinths and frame-linings	B
	Directly on the walls or on the ceilings On unperforated cable paths or trays	C
Multi-core cables	On corbels, ladder supports and perforated paths Directly on the walls, Suspended cables	E
Multi-core cables	On corbels, ladder supports and perforated paths Directly on the walls, Suspended cables	F

CORRECTION FACTOR K1		
Reference method	Cases of installation	K1
B	Cables embedded directly in a thermal insulated material	0.70
	Conduits embedded directly in a thermal insulated material	0.77
	Multi-core cables	0.90
	Spaces in buildings and gutters	0.95
C	Directly fixed on the ceiling	0.95
B, C, E, F	Other cases	1

Reference method	Arrangement of joint cables	CORRECTION FACTOR K2											
		Correction Factor K2											
		Number of circuits or multi-core cables											
B, C	Embedded inside the walls	1	2	3	4	5	6	7	8	9	12	16	20
C	Single layer on the walls, on the floors or on Unperforated trays	1.00	0.80	0.70	0.65	0.60	0.57	0.54	0.52	0.50	0.45	0.41	0.38
	Single layer fixed directly under ceiling	0.95	0.81	0.72	0.68	0.66	0.64	0.63	0.62	0.61	0.61		
E, F	Single layer on perforated horizontal trays or on vertical trays	1.00	0.88	0.82	0.77	0.75	0.73	0.73	0.72	0.72	0.72		
	Single layer on cable ladder supports or cloats	1.00	0.87	0.82	0.80	0.80	0.79	0.79	0.78	0.78	0.78		

Ambient Temperature (°C)	CORRECTION FACTOR K3		
	Insulator		
	Rubber	PVC	XLPE
10	1.29	1.22	1.15
15	1.22	1.17	1.12
20	1.15	1.12	1.08
25	1.07	1.07	1.04
30	1.00	1.00	1.00
35	0.93	0.93	0.96
40	0.82	0.87	0.91
45	0.71	0.79	0.87
50	0.58	0.71	0.82

## APPENDIX 6 (/Q3)

### RECOMMENDED SIMPLIFIED APPROACH FOR CABLE SIZING

Reference methods	Number of loaded conductors and type of insulation											
	2 PVC	3 PVC	3 XLPE	2 XLPE								
A1												
A2	3 PVC	2 PVC	3 XLPE	2 XLPE								
B1			3 PVC	2 PVC		3 XLPE		2 XLPE				
B2		3 PVC	2 PVC		3 XLPE	2 XLPE						
C			3 PVC		2 PVC	3 XLPE		2 XLPE				
E				3 PVC		2 PVC	3 XLPE		2 XLPE			
F					3 PVC		2 PVC	3 XLPE		2 XLPE		
	1	2	3	4	5	6	7	8	9	10	11	12
Size (mm <sup>2</sup> ) Copper												13
1.5	13	13.5	14.5	15.5	17	18.5	13.5	22	23	24	26	
2.5	17.5	18	19.5	21	23	25	27	30	31	33	36	
4	23	24	26	28	31	34	36	40	42	45	49	
6	29	31	34	36	40	43	46	51	54	58	63	
10	39	42	46	50	54	60	63	70	75	80	86	
16	41	43	48	53	58	61	66	73	77	84	91	
25	68	73	80	89	95	101	110	119	127	135	149	161
35				110	117	126	137	147	158	169	185	200
50				134	141	153	167	179	192	207	225	242
70				171	179	196	213	229	246	268	289	310
95				207	216	238	258	278	298	328	352	377
120				239	249	276	299	322	346	383	410	437
150					285	318	344	371	395	441	473	504
185					324	362	392	424	450	506	542	575
240					380	424	461	500	538	599	641	679
Size (mm <sup>2</sup> ) Aluminium												
2.5	13.5	14	15	16.5	18.5	19.5	21	23	24	26	28	
4	17.5	18.5	20	22	25	26	28	31	32	35	38	
6	23	24	26	28	32	33	36	39	42	45	49	
10	31	32	36	39	44	46	49	54	58	62	67	
16	41	43	48	53	58	61	66	73	77	84	91	
25	53	57	63	70	73	78	83	90	97	101	108	121
35					86	90	96	103	112	120	126	135
50					104	110	117	125	136	146	154	164
70					133	140	150	160	174	187	198	211
95					161	170	183	195	211	227	241	257
120					186	197	212	226	245	263	280	300
150						226	245	261	283	304	324	346
185						256	280	298	323	347	371	397
												447

Go on to the next page

**Appendix 7 (/Q4)**  
**DETERMINATION OF SHORT CIRCUIT CURRENT (Isc)**

The table below shows Isc at a point downstream, as a function of a known upstream fault-current value and the length and c.s.a. of the intervening conductors, in a 220/380V 3-phase system.

Copper 230 V / 400 V		Length of circuit (in metres)	Isc downstream (in kA)													
c.s.a. of phase conductors (mm²)	Isc upstream (in kA)		1.3	1.8	2.6	3.6	5.2	7.3	10.3	14.6	21	25	34	39	55	
1.5																
2.5																
4																
6																
10																
16																
25																
35																
47.5																
70																
95																
120																
150																
185																
240																
300																
2x120																
2x150																
2x185																
553x120																
3x150																
3x185																
Isc upstream (in kA)		Isc downstream (in kA)														
100	93	90	87	82	77	70	62	54	45	37	29	22	17.0	12.6	9.3	6.7
90	84	82	79	75	71	65	58	51	43	35	28	22	16.7	12.5	9.2	6.7
80	75	74	71	68	64	59	54	47	40	34	27	21	16.3	12.2	9.1	6.6
70	66	65	63	61	58	54	49	44	38	32	26	20	15.8	12.0	8.9	6.6
60	57	56	55	53	51	48	44	39	35	29	24	20	15.2	11.8	8.7	6.5
50	48	47	46	45	43	41	38	35	31	27	22	18.3	14.5	11.2	8.5	6.3
40	39	38	36	37	36	34	32	30	27	24	20	16.8	13.5	10.6	8.1	6.1
35	34	34	33	33	32	30	29	27	24	22	18.8	15.8	12.9	10.2	7.9	6.0
30	29	29	28	28	27	27	25	24	22	20	17.3	14.7	12.2	9.8	7.6	5.8
25	25	24	24	24	23	23	22	21	19.1	17.4	15.5	13.4	11.2	9.2	7.3	5.6
20	20	20	19.4	19.2	18.8	18.4	17.8	17.0	16.1	14.9	13.4	11.8	10.1	8.4	6.8	5.3
15	14.8	14.8	14.7	14.5	14.3	14.1	13.7	13.3	12.7	11.9	11.0	9.9	8.7	7.4	6.1	4.9
10	9.9	9.9	9.8	9.7	9.6	9.4	9.2	8.9	8.5	8.0	7.4	6.7	5.9	5.1	4.2	3.4
7	7.0	6.9	6.9	6.9	6.9	6.8	6.7	6.6	6.4	6.2	6.0	5.8	5.2	4.7	4.2	3.6
5	5.0	5.0	5.0	4.9	4.9	4.9	4.9	4.8	4.7	4.6	4.5	4.3	4.0	3.7	3.4	3.0
4	4.0	4.0	4.0	4.0	4.0	3.9	3.9	3.9	3.8	3.7	3.6	3.5	3.3	3.1	2.9	2.6
3	3.0	3.0	3.0	3.0	3.0	2.9	2.9	2.9	2.8	2.7	2.6	2.5	2.3	2.1	1.9	1.6
2	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	1.9	1.9	1.8	1.8	1.7	1.6	1.4	1.1
1	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	0.9	0.9	0.8	0.7	0.6
Aluminium 230 V / 400 V		Isc downstream (in kA)														
c.s.a. of phase conductors (mm²)	Isc upstream (in kA)	Length of circuit (in metres)														
2.5																
4																
6																
10																
16																
25																
35																
47.5																
70																
95																
120																
150																
185																
240																
300																
2x120																
2x150																
2x185																
553x120																
3x150																
3x185																
3x240																

Note: for a 3-phase system having 230 V between phases, divide the above lengths by  $\sqrt{3}$

## Selection of Multi 9 circuit breakers

APPENDIX 8a (Q4b)

Type of circuit breakers	TC16	TC16P	DPN <sup>(i)</sup>	DPN	C32H XC40	Reflex	C60a	C60N	C60H	C60L ≤25A	C60L 32-40A	C60L 50-63A	NC100H	NC6100LH
Rated current I <sub>r</sub> (A)	16 at 30°C	16 at 30°C	40 at 30°C	40 at 30°C	38 at 30°C	38 at 20°C	40 at 30°C	63 at 30°C	63 at 40°C	25 at 40°C	40 at 40°C	63 at 40°C	100 at 40°C	63 at 40°C
Rated voltage U <sub>r</sub> (V)	ac 50/60 Hz	240	240	240	Special	440	440	440	440	440	440	440	440	440
dc					Direct	250	250	250	250	250	250	250	250	250
Insulation voltage U <sub>i</sub> (V)					Current	500	500	500	500	500	500	500	500	500
Maximum withstand U <sub>m</sub> (kV)						6	6	6	6	6	6	6	6	6
Rated voltage U <sub>r</sub> (V)	Uimp rated voltage					1 + N	1 + N	1 + N	1 + N	1 + N	1 + N	1 + N	1 + N	1 + N
number of poles	I-1 + N	I-1 + N	I-1 + N	I-1 + N		2-3-4	1	2-3-4	1	2-3-4	1	2-3-4	1	2-3-4
Breaking capacity	NF C61410 EN 60898 (A eff.)	I <sub>cu</sub>	230V	3000	3000	4500	6000			3000	3000	6000	6000	10000
		I <sub>cs</sub>	400V							3000	3000	6000	6000	10000
		I <sub>es</sub>	230V/400V							3000	3000	6000	6000	10000
NF C63120 CEI 947.2 (kA eff.)	I <sub>cu</sub>	130V								10	20	50	50	100
		I <sub>cv</sub>	240V	4.5	4.5	6	7.5			5	10/10	20/15	30/25	50/20
		I <sub>es</sub>	415V									6	25/5	20/4
		I <sub>es</sub>	440V									20	15	10
		I <sub>es</sub>												630

## Selection of NS Compact circuit breakers

Type of circuit breakers	NS80	NS125E	NSA160	NS100	NS160	NS250	NS400
number of poles	3	3,4	3,4	2,3,4	2,3,4	2,3,4	3,4
Electrical characteristics according to CEI947-2 and EN60947-2							
Rated current I <sub>r</sub> (A) at 40°C	80	125	160	100	160	250	400
Insulation voltage U <sub>i</sub> (V)	750	750	750	750	750	750	750
Maximum withstand U <sub>m</sub> (kV)	8	8	8	8	8	8	8
Rated voltage U <sub>r</sub> (V)	ac 50/60 Hz	500	500	690	690	690	690
dc			250	500	500	500	500
Ultimate breaking capacity		H	N	H	L	N	H
I <sub>cu</sub> (kA <sub>eff</sub> )	ac 50/60Hz 220V/240V	10	25	85	150	150	150
	380V/415V	70	30	70	150	150	150
	440V	65	10	15	65	130	130
	500V	25	6	18	50	70	70
	525V	25		18	35	22	35
	660/690V	6		8	10	20	20
dc	250V			50	85	100	85
	500V			50	85	100	50